STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116711
Permit No.
Basin 137A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67912

1. OWNER Charlie Cox
MAILING ADDRESS HC 60 Box 34029 Rnd Mtn NV 89045
ADDRESS AT WELL LOCATION 200 Pole Line Road Rnd Mtn NV 89045
Subdivision Name: Ø County: NYE

2. LOCATION NE ¼ NW ¼ Sec 7 T 6 N/S R 41 E
PERMIT/WAIVER No. Ø 012-131-01
Issued by Water Resources Parcel No.
Latitude N38° 23.865 UTM E ☐ NAD 27
Longitude W117 25.122 N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel - Boulders		0	75	75
Hard Rock		75	95	20
Sand Boulders	X	95	160	65
Sand - Gravel	X	160	175	15
Hard Rock		175	190	15
Sand - Gravel	X	190	195	5
Hard Rock		195	198	3

7' of 8" steel casing was cemented over 6" pvc at surface

NAD27
38.397820° N
117.417778° W

RECEIVED 2013 MAY 20 AM 11:20 STATE ENGINEERS OFFICE

Date started: 5-16-2013, 20
Date completed: 5-17-2013, 20

7. Water Level
Static water level: 92 feet below land surface
Artesian Flow: 0 G.P.M. P.S.I.
Water Temperature: cold °F
Quality: good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2

9. WELL CONSTRUCTION
Depth Drilled 198 Feet Depth Cased 198 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	198	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6½	PVC	Sch 40	0	198

Perforations:
Type of perforation Saw cut
Size of perforation 1/8" x 3"
From 58 feet to 118 feet
From 138 feet to 198 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 50 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 198 ☐ Pumped ☒ Poured
Type: 1/4" minus
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps
Contractor
Address HC 61 Box 54 Hiko NV 89017
Contractor
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis
By driller performing actual drilling on-site or contractor
Date 5-17-2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627