STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116715
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67645

1. OWNER City of Fallon
MAILING ADDRESS 55 West Williams Ave.
Fallon NV 89406

ADDRESS AT WELL LOCATION 1401 New River Parkway
Fallon NV 89406
Subdivision Name: —
County: Churchill

2. LOCATION SW¼ SE ¼ Sec 32 T 19 N/S R 29 E
PERMIT/WAIVER No. NV0020061 | 001 781 22
NPDES Issued by Water Resources Parcel No.

Latitude 39°27'48.24"
Longitude 118° 45' 03.21"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
brown silty sand		0	6'	6'
brown clayey sand	9.5'	6'	18'	12'
brown ~~fine~~ sand silty		18'	19'	1'

NAD27
39.463482°N
118.749907°W

Date started: 4/24, 20 13
Date completed: 4/24, 20 13

9. WELL CONSTRUCTION
Depth Drilled 19' Feet Depth Cased 19' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.5	Inches	19	Feet	0	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch 40	19	0

Perforations:
Type of perforation slotted screen
Size of perforation .010
From 19 feet to 4 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 2 to 1 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 1 to 0 ☐ Pumped ☒ Poured
☐ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 19 to 3 ☐ Pumped ☒ Poured
Type: SRI Supreme #12
Bentonite Chips: ☒ Yes ☐ No 3 to 2 ☐ Pumped ☒ Poured
Type: Hydro 3/8 medium chips

7. Water Level
Static water level: 9½' feet below land surface
Artesian Flow: — G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. N/A WELL TEST DATA N/A
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DALE LEHMAN
Contractor
Address 520 Edison Way
Contractor
Reno NV 89502
Nevada contractor's license number issued by the *State Contractor's Board* 0077413
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-1976
Signed Dale Lehman
By driller performing actual drilling on site or contractor
Date 4/29/13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY