STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116733
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70136

1. OWNER Andy Wilkerson
MAILING ADDRESS 5630 Testhill Dr.
Winnemucca NV. 89445

ADDRESS AT WELL LOCATION 5630 Testhill Dr.
Winnemucca NV.
Subdivision Name: JB Estates County: Humboldt

2. LOCATION SE ¼ SE ¼ Sec 2 T 35 N/S R 37 E
PERMIT/WAIVER No. 013-837-08
Issued by Water Resources Parcel No.

Latitude N40°55.923 UTM E
Longitude W117°45.476 N
[x] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [x] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand	NO	0	2	2
Hard brown clay	NO	2	10	8
Coarse gravel sand	NO	10	80	70
Gravel Clay sand	YES	80	200	120

NAD27
40.932050°N
117.774600°W

RECEIVED 2013 JUN 11 AM 11:46 STATE ENGINEERS OFFICE

Date started: 5-29, 20 13
Date completed: 5-31, 20 13

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
6 5/8	PVC	Schedule 40	20	200

Perforations:
Type of perforation Slot
Size of perforation .20
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 0 to 50 [ ] Pumped [x] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [x] Yes [ ] No 50 to 200 [ ] Pumped [x] Poured
Type:
Bentonite Chips: [ ] Yes [x] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 70 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	NA	4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 26778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 6-6-13

(Rev. 03-08)

USE ADDITIONAL SHEETS IF NECESSARY