STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116759
Permit No.
Basin No. 153

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69274
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME ~~Danny~~ Kenneth Sanders
MAILING ADDRESS P.O. Box 422
Eureka, NV 89316

DETAILED ADDRESS AT WELL LOCATION 941 Rose Road
Eureka, NV 89316
Subdivision Name: *County:* Eureka

2. PLS LOCATION SE ¼ SE ¼ 3 Sec 23N N/S 54 E
PERMIT/WAIVER NO. 607-400-18
Issued by Water Resources *Current Parcel No.*

Latitude 39.89904 N UTM E ☐ NAD 27
Longitude 115.86816 W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# UNKNOWN
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Gravel			180	210	30
Clay			210	218	8
Gravel Sand		XX	218	240	22
Deepens Unknown	well	log			
39.899040°N	NAD	27			
115.868160°W					

Date started: 20-Sep, 20 12
Date completed: 21-Sep, 20 12

9. WELL CONSTRUCTION
Depth Drilled: 240 Feet Depth Cased: 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	180	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5.563	10.79	.188	240	100

PERFORATIONS:
Type of perforation: Mill Cut
Size of perforation: 0.1875
From 240 Feet To 200 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☐ Sanitary Seal to
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 140 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: Unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc
Contractor
Address P.O. Box 1265 Fallon, NV 89407
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2307

Signed:
By driller performing actual drilling on site or contractor
Date: 10/3/2012

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY