STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 11674
Permit No.
Basin No. 044

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69691

1. OWNER/CLIENT NAME Martin, Frank
MAILING ADDRESS 533 Ryndon Unit 9
Elko, NV 89801

DETAILED ADDRESS AT WELL LOCATION Walnut St
Ruby View Ranchos Elko

2. PLS LOCATION SE ¼ SE ¼ 29 Sec 37N N/S 57 E
PERMIT/WAIVER NO. 072-006-012

Latitude W115*34.067 UTM E ☐ NAD 27
Longitude N41*03.631 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Last	Water	From	To	Thickness
sand/gravel			0	110	110
silt stone			110	270	160
gravel		X	270	290	20
silt stone			290	310	20
gravel			310	320	10
silt stone			320	330	10
gravel			330	350	20

NAD27
46.0605980°N
115.5668840°W

RECEIVED 2013 JUN 14 AM 11:01 STATE ENGINEERS OFFICE

Date started: 28-May, 20 13
31-May, 20 13

9. WELL CONSTRUCTION
Depth Drilled: 350 Feet Depth Cased: 350 Feet

		From	To
10 5/8	Inches	0 Feet	350 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+18"	350

PERFORATIONS:
Type of perforation: mill slot
Size of perforation: 3/16 x 3
From 330 Feet To 350 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	5	to 55		
☒ Neat Cement	5	to 20	☐ Pumped	☒ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	20	to 55	☐ Pumped	☒ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	55	to 350	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 224 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
60		4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Alternative Drilling Co LLC (Contractor)
Address P.O. Box 281166, Lamoille, NV 89828 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 73955
Nevada well driller's license number as issued by the 2465
Signed: Logan Rosenthal
Date: 6-6-13

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY