STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 1116854
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69859

1. OWNER GHEORHGE LAPUSTE
MAILING ADDRESS 5852 CALPINE DR
SAN JOSE, CA 95123

ADDRESS AT WELL LOCATION 2824 HENNING LANE
MINDEN, NV 89423
Subdivision Name: County: Douglas

2. LOCATION SW ¼ SW ¼ Sec 26 T 14N N/S R 20 E
PERMIT/WAIVER No. DOM 13-29 (Issued by Water Resources) 1420-26-401-016 (Parcel No.)
Latitude 39.04324*N
Longitude 119.712514*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 6 5/8 WELL		0	198	198
MEDIUM OBSIDIAN SANDS		198	235	37
BROWN DG SANDS HARD		235	270	35
FRACTURED DG GRAVELS	XX	270	300	30

NAD27
39.04331°N
119.711504°W
Deepens well logunknown

Date started: 17-Jun, 20 13
Date completed: 20-Jun, 20 13

RECEIVED 2013 JUN 25 AM 11:36 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 102 Feet Depth Cased 102 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	198	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	3.75	.216	180	300
SDR 21				

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation .032
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 148' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15-18	63	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 55548 ~~005548~~
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed (By driller performing actual drilling on site or contractor)
Date 06/22/2013

(Rev. 05-09)

USE ADDITIONAL SHEETS IF NECESSARY