

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY

Log No. 116911
 Permit No. _____
 Basin 104

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 67534

1 OWNER JIM WAGNER
 MAILING ADDRESS 819 W. IRIS DR
NW GILBERT, AZ 85233

ADDRESS AT WELL LOCATION 979 KOONTZ LANE
CARSON CITY, NV 89701
 Subdivision Name: _____ County: Carson City

2 LOCATION SE ¼ NW ¼ Sec 29 T 15N N/S/R 20 E
 PERMIT/WAIVER No. SE 009-137-06
Issued by Water Resources Parcel No.

Latitude 39.13348°N UTM E NAD 27
 Longitude 119.75822°W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? NO
 Is there an existing well log? NO
 If yes, what is replacement well NO? _____
 If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
 Depth Drilled 93 Feet Depth Cased 93 Feet

7 WELL PLUGGING PROCEDURE
 Was well cleaned out to total depth? yes no

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	93

If well was not cleaned out to total depth, please explain why: _____
 Was the well contaminated? yes no
 Was the casing pulled? yes no
 Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Size of perforation	From	To
FACTORY SAW CUT	3X 3/32	73 feet	93 feet

Additional Perforations:

Type of perforator used:	From	To	Number of perfs per linear foot
MILLS KNIFE	50 feet	85 feet	4

5 WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality BAD

8 WELL PLUGGING MATERIALS
Material Used
 From 0 feet to 93 feet **NEAT CEMENT** Pumped Poured
 From _____ feet to _____ feet Pumped Poured

6 Additional Notes or Comments
PULLED OUT OLD PUMP, PERFORATED FROM 50' TO 84'
PLACED 2' TREEMIE PIPE TO BOTTOM AND PUMPED
WITH NEAT CEMENT TO SURFACE.

Neat Cement Fluid Weight 94/4 lbs/gal
 Bentonite Grout _____ % bentonite
 Date Started 11/28/2011
 Date Completed 11/28/2011

Plugs an known Well log
39.133571°N NAD 27
119.757206°W Dec 1 Day

9 DRILLER'S CERTIFICATION
 This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
 Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
 Address 20 KIT KAT DRIVE
Contractor
CARSON CITY, NV 89706
 Nevada contractor's license number _____
 issued by the State Contractor's Board 0055548
 Nevada driller's license number issued by the _____
 Division of Water Resources, the on-site driller 1905
 Signed [Signature]
By driller performing actual drilling on site of contractor
 Date 11/28/2011

(Rev. 05-09)

USE ADDITIONAL SHEETS IF NECESSARY