

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 116436
Permit No. _____
Basin 099

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66136

1 OWNER Karen Miller-Regnier ADDRESS AT WELL LOCATION 4365 Gander Lane
MAILING ADDRESS 4365 Gander Lane Washoe Valley, NV
Washoe Valley, NV 89704 Subdivision Name: New Washoe City County: Washoe

2 LOCATION NE 1/4 NE 1/4 Sec 05 T 16N N/S R 20 E Latitude 39.28567 UTM E NAD 27
PERMIT/WAIVER No. DOM 13-27 1050-435-24 Longitude 119.75438 N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3 TYPE OF WELL Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? Yes
If yes, what is replacement well NOI? 70576

Is there an existing well log? No
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled 222 Feet Depth Cased 112 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"		.156	+ 2	112

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

If casing was left in place, please show where additional perforations were made:
Additional Perforations: _____

Existing Perforations:
Type of perforation None, no casing
Size of perforation below 112'

From	feet to	feet

Type of perforator used: Mills Knife

From	feet to	feet	Number of perfs per linear foot
From <u>63</u>	feet to <u>112</u>	feet	<u>4</u>
From _____	feet to _____	feet	_____
From _____	feet to _____	feet	_____
From _____	feet to _____	feet	_____
From _____	feet to _____	feet	_____
From _____	feet to _____	feet	_____

5 WATER LEVEL
Static water level 138 feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From <u>0</u>	feet to <u>20</u>	feet	<u>Neat Cement</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From <u>20</u>	feet to <u>222</u>	feet	<u>Bentonite</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet	_____	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet	_____	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet	_____	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet	_____	<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
We attempted to perforate well, but there was no well casing below 112 feet. so we perforated the steel casing from 112 feet to 63 feet. We were unable to perforate above 63 feet due to sanitation seal. Installed tremie pipe and pumped 30% Bentonite from bottom 222 feet to 20 feet. from 20 feet to surface we pumped Neat cement.

Neat Cement Fluid Weight 15 lbs/gal
Bentonite Grout 30% % bentonite
Date Started July 02, 2013
Date Completed July 03, 2013

Washoe County Permit #WLI30031
Washoe County Well Construction Inspection Form attached.
Plugs well log unknown
Replaced by well log # 116437
NAD 27
39.2856759° N
119.7533630° W

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Fundin Pump & Well Service Contractor
Address 4030 Eastlake Blvd. Contractor
Washoe Valley, NV 89704
Nevada contractor's license number _____
issued by the State Contractor's Board 7472038
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2205
Signed Norme Fundin
By driller performing actual drilling on site or contractor
Date July 05, 2013

RECEIVED
2013 JUL -9 AM 10:38
DIVISION OF WATER RESOURCES OFFICE

WASHOE COUNTY DISTRICT HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL SERVICES

WELL CONSTRUCTION INSPECTION FORM

OWNER Bruce Woolsey DATE 7/28/81
ADDRESS OR PARCEL NUMBER 4365 Garden Lane
PERMIT NO. #1580 WELL DRILLED BY Sina Pump
DRILLING METHOD — ROTARY CABLE TOOL _____ OTHER _____
DEPTH 322' CASING SIZE 6" MATERIAL 156
GRAVEL PACKED NO SANITARY SEAL IN PLACE 8-3-81
SAMPLES COLLECTED _____ BACTERIOLOGICAL _____ CHEMICAL _____
APPROXIMATE GPM 12
ESTIMATED BY Frank Strasser
SET-BACK FROM SEPTIC SYSTEM/S (IF IN PLACE) _____

REMARKS: Well had already been drilled, and ready to seal on 8-3-81. No advance notice that well was going in at above address. Both driller & owner of property said they informed office of intent to drill at time permit was obtained, 8-3-81 by. Matched seal poured 8-3-81 by.

INSPECTOR B. Gorman DATE OF FIRST INSPECTION 7-3-81
INSPECTOR B. Gorman DATE OF FINAL INSPECTION 8-3-81
(Inspection request)

Request for 1st inspection: Date _____ Time _____
Person calling _____ On Site _____
Request for final inspection: Date _____ Time _____
Person calling _____ Time _____
Date and time to seal well _____

RECEIVED
2013 JUL -9 AM 10:38
STATE ENGINEERS OFFICE