STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116953
Permit No.
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69075

1. OWNER Claude J. Rose
MAILING ADDRESS HC 33 Box 33200
Ely, NV 89301

ADDRESS AT WELL LOCATION About 1 mile east of Hwy 93 on 185 N St.
Subdivision Name:
County: White Pine

2. LOCATION SE ¼ NW ¼ Sec 30 T 17 N/S R 64 E
PERMIT/WAIVER No. 10-340-17
Issued by Water Resources Parcel No.

Latitude 39.31162
Longitude 114.81483
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
5% Clay, 5% Sand, 90% Gravel		0	10	10
5% Clay, 5% Sand, 90% Gravel water bearing	X	10	80	70
2% Clay, 5% Sand, 93% Gravel, wht BIF		80	160	80

NAD 27
39.31168° N
114.813980° W

Date started: July 1, 20 13
Date completed: July 3, 20 13

7. Water Level
Static water level: 75 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 Hour

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8"	inches	0 Feet	160 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		.250	+2	20
6.625		SDR17	20	160

Perforations:
Type of perforation mill
Size of perforation 1/8 x 2 1/2 x 6
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 160 ☐ Pumped ☒ Poured
Type: 3/8" Gravel -2 yards-
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Brothers Drilling (Contractor)
Address PO Box 965 (Contractor)
Enterprise, UT 84725
Nevada contractor's license number issued by the State Contractor's Board 0064754
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 24911
Signed (By driller performing actual drilling on-site or contractor)
Date July 9, 2013

RECEIVED 2013 JUL 11 AM 11:11 STATE ENGINEERS OFFICE

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627