

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116983
Permit No. 82273
Basin 029

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69778

1. OWNER EGGER ENTERPRISES, LLC ADDRESS AT WELL LOCATION Turn in off Hwy 140 toward Egger's house. Go 1 mile, turn right and go 1 mile to the well.
MAILING ADDRESS 398 Hwy 140 Winnemucca, NV 89445

2. LOCATION SE 1/4 NE 1/4 Sec 27 T 44N N1/2 R 31 E Latitude 41deg 39.609min UTM E NAD 27
PERMIT/WAIVER No. 82273 Longitude 118deg 29.019min N NAD 83/WGS 84
Issued by Water Resources Parcel No. Subdivision Name: County: Humboldt

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other...
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Course Gravel		0	6	6
Granite Sand		6	13	7
Course Gravel		13	32	19
Granite Sand		32	47	15
Course Gravel		47	95	48
Silt & Sand With Gravel Stringers		95	230	135
Silt With Large Granite Sand		230	310	80
Silt & Sand With Gravel Stringers		310	505	195
Sand & Gravel		505	520	15
Silt		520	540	20
Sand & Gravel		540	560	20
Silt		560	590	30
Silt & Sand With Gravel Stringers		590	730	140
Hard Silt With Sand & Grvl Strgr		730	850	120

NAD27
41.6602520N
118.4826535W

RECEIVED
2013 JUL 12 AM 10:30
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Depth Drilled 850 Feet Depth Cased 840 Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
42	0	50	Feet
28	50	850	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
36		.250	0	50
16		.250	+1	160
16		.312	160	840

Perforations:

Type of perforation _____ Mill Slot
Size of perforation _____ 250 x 3in

From 160 feet to 840 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50ft Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 0 feet to 850 feet

9. WATER LEVEL

Static water level 115 feet below land surface
Artesian flow NA G.P.M. _____ P.S.I. _____
Water temperature 63 °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AMS Enterprises, LLC Contractor
Address 398 Hwy 140, Winnemucca, V 89445 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0077730
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140
Signed JEFFOD JOHNSON By [Signature]
By driller performing actual drilling on site or contractor
Date _____

Date started 18-Jun, 20 13
Date completed 21-Jun, 20 13

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

PL	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
PL 460ft	200	355	8

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY