STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117030
Permit No.
Basin 137B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67451

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain, Nevada, 89045

ADDRESS AT WELL LOCATION Round Mountain Pit south ramp
Well Name:DV-13-01

2. LOCATION NW ¼ NW ¼ Sec 30 T 10N N/S R 44 E
PERMIT/WAIVER No. mo1894 (Issued by Water Resources) Parcel No.

Latitude
Longitude
Subdivision Name: N/A
UTM E 492374.7 ☑ NAD 27
N 4283312.5 ☐ NAD 83/WGS 84
County: Nye

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☐ Air ☐ Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
dump fill		0	21	21
alluvium		21	215	194
densely welded tuff (type I)	250	215	570	355
moderately welded tuff (type IX)		570	655	85
poorly welded tuff (type II)		655	750	95

RECEIVED 2013 JUL 22 AM 10:32 STATE ENGINEERS OFFICE

NAD27
38.694483°N
117.812139°W

Date started 29-Jun, 20 13
Date completed 2-Jul, 20 13

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
750	5	na	30 min

8. WELL CONSTRUCTION
Depth Drilled 750 Feet Depth Cased 750 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14.75	Inches	0	Feet	21	Feet
6.75	Inches	21	Feet	750	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	22.37	.25	0	21
2.375	.96	sch 80	-2	750

Perforations:
Type of perforation slotted
Size of perforation 0.02
From 100 feet to 750 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 95 feet to 750 feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow No G.P.M N/A P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name National EWP (Contractor)
Address 580 West Silver Street (Contractor)
Elko Nevada 89801
Nevada contractor's license number issued by the *State Contractor's Board* 00075355
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2457
Signed (By driller performing actual drilling on site or contractor)
Date 7/8/2013

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY