STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117142
Permit No. 82782T
Basin No. 88

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69467
WELL NAME (If applicable): 69443

1. OWNER/CLIENT NAME International Community of Christ
MAILING ADDRESS 643 Ralston St, Reno, NV 895303

DETAILED ADDRESS AT WELL LOCATION 115 Castle Peak Ln, Reno
Subdivision Name: County: Washoe

2. PLS LOCATION NE ¼ SE ¼ 35 Sec 22 N/S 19 E
PERMIT/WAIVER NO. 82782T (issued by Water Resources) 079-440-14 (Current Parcel No.)

Latitude 39.72831 UTM E ☐ NAD 27
Longitude 119.8111 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ ~~Domestic~~ ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☒ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Sand			0	17	17
DG			17	448	431
Broken granite		W	448	475	27

NAD27
39.72880°N
119.81075°W

RECEIVED 2013 JUL 22 AM 11:44 STATE ENGINEER'S OFFICE

Date started 24-Jun , 20 13
Date completed: 2-Jul , 20 13

9. WELL CONSTRUCTION
Depth Drilled: 475 Feet Depth Cased: 475 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	65	Feet
8 3/4	Inches	65	Feet	475	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.97	188	+2	475

PERFORATIONS:
Type of perforation: factory mill slot
Size of perforation: 3/32
From 454 Feet To 475 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☐ Sanitary Seal		to		
☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 63	☐ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	63	to 475	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 360 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
10	40	3
20	65	
25	90	
25	115	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Steve McKay (Contractor)
Address 4850 Joule St A-5, Reno, NV 89502 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 14170
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2121
Signed: (By driller performing actual drilling on site or contractor)
Date: 7/2/2013

(Rev. 09-12)

USE ADDITIONAL SHEETS IF NECESSARY