STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117186
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36894

1. OWNER Boulevard Associates
MAILING ADDRESS P.O. Box 617905
Chicago, IL 60661-7905

ADDRESS AT WELL LOCATION 3600 S. Maryland Pkwy
MW-19D Paradise

2. LOCATION SW ¼ NW ¼ Sec 14 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-14-213-002
Issued by Water Resources Parcel No.

Latitude 36 07'26.30"N
Longitude 114 08'00.70"W
Subdivision Name: 5 DSTP
UTM E
N
☐ NAD 27 ☑ NAD 83/WGS 84
County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	2	2
Silty Sand		2	16	14
Sandy Clayey Silt		16	20	4
Clayey Sand		20	29	9
Caliche		29	30	1
Sandy Silt		30	37	7
Clay		37	39	2
Silty Gravel		39	41	2
Clay		41	45	4
Clayey Gravel		45	56	11
Sandy Clay		56	60	4
Silty Clay		60	69	9
Silty Sand		69	75	6
Clay		75	84	9
Silty Clay		84	86	2
Sandy Clay		86	90	4
Clayey Sandy Silt		90	94	4
Clay		94	99	5
Sandy Clay		99	104	5

Date started 12-Jan , 20 13
Date completed 15-Jan , 20 13

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR/SNBO
RECEIVED
MAR 01 2013

8. WELL CONSTRUCTION
Depth Drilled 104 Feet Depth Cased 102 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8	Inches	50	Feet	104	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		Sch 80	0	51
2.375		Sch 80	0	70
2.375		Sch 80	0	102

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02
From 31 feet to 51 feet
From 60 feet to 70 feet
From 92 feet to 102 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 25
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 28,57,89 feet to 53,72,104 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling L.P. (Contractor)
Address 555 S. Harbor Blvd (Contractor)
La Habra, CA 90631
Nevada contractor's license number issued by the *State Contractor's Board* C23 0073966
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2432
Signed Michael Thomas (By driller performing actual drilling on site or contractor)
Date 2/26/13

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY

36,123972 NAD 27
-114,133527
5