STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117187
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36894

1. OWNER Boulevard Associates
MAILING ADDRESS P.O. Box 617905
Chicago, IL 60661-7905

ADDRESS AT WELL LOCATION 3600 S. Maryland Pkwy
MW-20D Paradise

2. LOCATION SW ¼ NW ¼ Sec 14 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-14-213-002
Issued by Water Resources Parcel No.

Latitude 36 07'25.86"N
Longitude 114 08'01.74"W
Subdivision Name: 5 DSB
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	2	2
Sand		2	9	7
Caliche		9	11	2
Sand		11	22	11
Silty Sand		22	24	2
Caliche		24	26	2
Clay		26	30	4
Silty Sand		30	37	7
Sand		37	39	2
Silty Sand		39	43	4
Clay		43	50	7
Sandy Silt		50	65	15
Silty Clay		65	66	1
Clay		66	81	15
Sandy Silt		81	85	4
Clayey Silt		85	87	2
Sandy Silt		87	90	3
Silty Clay		90	95	5
Silty Sand		95	100	5

Date started 8-Jan , 20 13
Date completed 10-Jan , 20 13

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR/SNBO RECEIVED MAR 01 2013

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 Inches	50 Feet	100 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		Sch 80	0	45
2.375		Sch 80	0	65
2.375		Sch 80	0	100

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02
From 25 feet to 45 feet
From 55 feet to 65 feet
From 90 feet to 100 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 19
Placement Method: ☑ Pumped ☐ Poured
Gravel Packed: ☑ Yes ☐ No
From 22,52,87 feet to 49,84,100 feet

Seal Type:
☐ Neat Cement
☑ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling L.P. (Contractor)
Address 555 S. Harbor Blvd (Contractor)
La Habra, CA 90631
Nevada contractor's license number issued by the *State Contractor's Board* C23 0073966
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2432
Signed Michael Thomas (By driller performing actual drilling on site or contractor)
Date 2/26/13

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY

36.12385
-114.133816
5
NAD27