STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117191
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36196

1. OWNER Boulevard Associates
MAILING ADDRESS P.O. Box 617905
Chicago, IL 60661-7905

ADDRESS AT WELL LOCATION 3600 S. Maryland Pkwy
Paradise

2. LOCATION SW ¼ NW ¼ Sec 14 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-14-213-002
Issued by Water Resources Parcel No.

Latitude 36.124062
Longitude 115.133743
Subdivision Name:

UTM E
N
☐ NAD 27
☑ NAD 83/WGS 84
County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	2	2
Silty Sand		2	8	6
Sandy Silt		8	20	12
Silty Sand		20	22	2
Caliche		22	24	2
Silt		24	28	4
Sand w/ Gravel		28	32	4
Silt		32	34	2
Silty Clay		34	40	6
Sandy Clayey Silt		40	44	4
Silty Clay		44	48	4
Clayey Sandy Silt		48	52	4
Silty Sand		52	54	2
Clayey Silt		54	60	6
Silty Sand		60	64	4
Silty Clay		64	70	6

DCNR/DWR/SNBO
RECEIVED
APR 19 2013

Date started 4/8/2013 , 20 13
Date completed 8-Apr , 20 13

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 70 Feet Depth Cased 61,51,36,30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	70	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1.050		Sch 80	0	30.5
1.050		Sch 80	0	36.5
1.050		Sch 80	0	51

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02

From	27.5	feet to	30.5	feet
From	33.5	feet to	36.5	feet
From	47	feet to	51	feet
From	58	feet to	61	feet
From		feet to		feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 26
Placement Method: ☑ Pumped ☐ Poured
Gravel Packed: ☑ Yes ☐ No
From 27,33,46,57 feet to 31,38,54,63 feet

Seal Type:
☐ Neat Cement
☑ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling L.P. (Contractor)
Address 4590 Copper Sage St (Contractor)
Las Vegas, NV 89115
Nevada contractor's license number issued by the *State Contractor's Board* C23 0073966
Nevada driller's license number issued by the Division of ~~Water Resources~~, the ~~*on-site driller*~~ 2381
Signed
By driller performing actual drilling on site or contractor
Date 4-18-13

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY

36.1240902
-115.1329108