STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117193
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37029

1. OWNER Corner Investment Propco LLC
MAILING ADDRESS 1 Ceasars Palace Dr.
Las Vegas Nv 89109

ADDRESS AT WELL LOCATION 3595 S. Las Vegas Blvd
Las Vegas Nv 89109

2. LOCATION NW ¼ NW ¼ Sec 21 T 21S N/S R 61 E
PERMIT/WAIVER No. MC-2949 (Issued by Water Resources) 162-21-101-003 Parcel No.

Latitude 36.115036
Longitude -115.169430
UTM E
N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name:
County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... HAS

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
asphalt		0	.5	1
clay with sand		.5	3	3
clay with sand fine grained		3	4	1
sand with gravel		4	5	1
caliche		5	12	7
sandy clay		12	15.5	4
sandy clay with fine sands		15.5	16	1
caliche		16	17	1
sandy clay		17	19	2
caliche		19	23	4
sandy clay		23	25	2
sandy clay with sand	25.7	25	28	3
clay with gravel		28	30	2
clay with trace of sand		30	32	2
silt with sand		32	33.5	2

Date started 2/15/2013 , 20 12
Date completed 2/15/2013 , 20 12

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 33.5 Feet Depth Cased 33 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	33.5	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	pvc	sch40	0	33

Perforations:
Type of perforation Machine Slots
Size of perforation 0.02
From 33 feet to 17 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☑ Poured
Gravel Packed: ☑ Yes ☐ No
From 33.5 feet to 15 feet

Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

9. WATER LEVEL
Static water level 25.7 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Service, LLc (Contractor)
Address 7150 Placid Street (Contractor)
Las Vegas, Nv 89119
Nevada contractor's license number issued by the *State Contractor's Board* 51266
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2490 Ltd
Signed (By driller performing actual drilling on site or contractor)
Date 3/1/2013

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY

DCNR/DWR/SNBC RECEIVED MAR 06 2013

36.1150646
-115.1685974
NAD27