STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117206
Permit No.
Basin No. 162

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34598
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Pearly M. Robbins/Robert Cornett
MAILING ADDRESS 2841 S. Red Rock Dr.
Pahrump, NV 89048

DETAILED ADDRESS AT WELL LOCATION 2841 S. Red Rock Dr.
Pahrump, NV 89048
Subdivision Name: Calvada Valley,Ut5,L14Blk22 *County:* Nye

2. PLS LOCATION SE ¼ SE ¼ 29 Sec 20S N/S 53 E
PERMIT/WAIVER NO. 40-382-06
Issued by Water Resources *Current Parcel No.*

Latitude N36°10.669 UTM E 2572' ☐ NAD 27
Longitude W116°02.150 UTM N 14' ☐ NAD 83 (WGS 84)

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# 42236
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Gravel			119	142	23
Brown clay			142	166	24
Gray Clay		X	166	176	10
Brown clay		X	176	200	24

Date started: 4-Apr , 20 13
Date completed: 7-Apr , 20 13

DCNR/DWR/SNBO
RECEIVED
APR 16 2013

9. WELL CONSTRUCTION
Depth Drilled: 81 Feet Depth Cased: 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	119	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.92	.28	100	200

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/4" width 4" long
From 140 Feet To 200 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☐ Sanitary Seal to
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 88 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Jim Pike Well Drilling, LLC
Contractor
Address P. O. Box 56 Pahrump, NV 89041
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 17563A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1324

Signed:
By driller performing actual drilling on site or contractor
Date: 12-Apr-13

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY

36.177816
-116.2149 NAD 27