

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117284
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36828

1. OWNER Green Valley Commercial LLC ADDRESS AT WELL LOCATION N/A
MAILING ADDRESS 901 W. Green Valley Pkwy #300
Henderson NV 89074-7105 Subdivision Name: _____ County: Clark

2. LOCATION SW 1/4 SW 1/4 Sec 32 T 21 N R 62 E Latitude 36°4'19.60"N UTM E NAD 27
PERMIT/WAIVER No. H-000278 161-32-412-002 Longitude 115°44'2.58"W N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	5	5
TYPE		5	2	1.5
clay sand w/gravel		2	5	3
caliche		5	6	1
sand w/clay		6	8	2
caliche		8	9	1
sand w/clay		9	14	5
caliche		14	15	1
sand w/gravel		22	22	7
caliche very hard		22	32	10
sand w/clay	23	32	35	3
caliche		35	36	1
sand gravel/cobble		36	42	6

9. WELL CONSTRUCTION

Depth Drilled 42' Feet Depth Cased 42' Feet

HOLE DIAMETER (BIT SIZE)

8 Inches From 0 Feet To 42' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>42</u>

Perforations:

Type of perforation Factory slot

Size of perforation 0.20

From 22 feet to 42 feet

From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured

Cement Grout 1 to 18 Pumped Poured

Concrete Grout to _____ Pumped Poured

≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 20 to 42 Pumped Poured

Type: # 3

Bentonite Chips: Yes No 18 to 20 Pumped Poured

Type: Hole plug

Date started: 5/7/13, 20 13
Date completed: 5/7, 20 13

7. Water Level

Static water level: 23 feet below land surface

Artesian Flow: _____ G.P.M. _____ P.S.I.

Water Temperature: _____ °F

Quality: _____

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Elite Drilling Inc. Contractor

Address 4255 W. Post rd. Contractor

Las Vegas, NV 89118

Nevada contractor license number 0054931

issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869

Signed [Signature]

By driller performing actual drilling on-site or contractor

Date 5/9/13