

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 117330
Permit No. _____
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67692 1

1 OWNER South Maine Mobile Home Park
MAILING ADDRESS 2500 E Foothill Blvd, Suite 505
Pasadena, CA 91107

ADDRESS AT WELL LOCATION 1055 S Maine St
Fallon, NV 89406
Subdivision Name: _____ County: Churchill

2 LOCATION NE 1/4 SW 1/4 Sec 31 T 19N N/S R 29 E
PERMIT/WAIVER No. 007-731-09
Issued by Water Resources Parcel No. _____

Latitude 39.46474 N UTM E _____ NAD 27
Longitude -118.77567 W N _____ NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? No
Is there an existing well log? No
If yes, what is replacement well NOI? _____
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12			0	21

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____
Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:
Type of perforation N/A
Size of perforation _____
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Additional Perforations:
Type of perforator used: Mill Knife
From 21 feet to 0 feet Number of perfs per linear foot 4
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

5 WATER LEVEL
Static water level 10 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool ° F Quality unknown

8 WELL PLUGGING MATERIALS
Material Used
From 21 feet to 0 feet Neat Cement Pumped Poured
From _____ feet to _____ feet Neat Cement Pumped Poured
From _____ feet to _____ feet Neat Cement Pumped Poured
From _____ feet to _____ feet Neat Cement Pumped Poured
From _____ feet to _____ feet Neat Cement Pumped Poured
From _____ feet to _____ feet Neat Cement Pumped Poured

6 Additional Notes or Comments
Pumped cement from bottom to top.

Neat Cement Fluid Weight 15.6 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 10/3/2011
Date Completed 10/3/2011

* Original well log unknown
39.464822° N NAD27
118.7741085° W Dec 1 Deg
STATE ENGINEERS DIVISION
2011 OCT 25 PM 10:53

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed *Wag...*
Date 10/7/2011

(Rev. 05-09)

USE ADDITIONAL SHEETS IF NECESSARY