STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117341
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66604

1. OWNER Westridge Homes / Allison Beekhof
MAILING ADDRESS 1528 HWY 395 GV NV
ADDRESS AT WELL LOCATION 610 Darkhorse GV

2. LOCATION ~~SW~~ NW ¼ ~~SW~~ NE ¼ Sec 25 T 12N N/S R 20 E
PERMIT/WAIVER No. 1220-25-501-031 (Issued by Water Resources) Parcel No.
Latitude 38.52 765 Longitude 119,41 053 UTM E N
☑ NAD 27 ☐ NAD 83/WGS 84
Subdivision Name: County: Douglas

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other...

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC ☐ Air ☐ Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
cobbles		0	15	15
rock		15	33	18
clay		33	45	12
rock and cobbles		45	158	113
sorted color and size gravel		158	176	18
cobbles and gravel		176	250	74
n 38, 52.765				
w 119, 41.053				

Date started 10/4/2011 , 20
Date completed 10/6/2011 , 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200 ft	20-25	n/a	2.5

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	53	Feet
9 7/8	Inches	53	Feet	250	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	20
6 5/8		sdr21	20	250

Perforations:
Type of perforation grinder cut
Size of perforation 3x3/64
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 53
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 53 feet to 250 feet

9. WATER LEVEL
Static water level 124 feet below land surface
Artesian flow n/a G.P.M 20-25 P.S.I
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blain Drilling (Contractor)
Address PO Box 1255 CC NV 89702 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 46498
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2134
Signed (by driller performing actual drilling on site or contractor)
Date 11/4/2011

(Rev. 06/10) USE ADDITIONAL SHEETS IF NECESSARY

38.879417°N NAD27
119.684217°W Dec/Deg