STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117347
Permit No. 21078
Basin 069

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69607

1. OWNER Fred Stewart
MAILING ADDRESS PO Box 14 Paradise Valley, NV

ADDRESS AT WELL LOCATION Wheels Well
Paradise Valley, NV
Subdivision Name: N/A County: Humboldt

2. LOCATION NE¼NW¼ Sec20T41N/ R40E
PERMIT/WAIVER NO: Per 21078 Cert 6175 (Issued by Water Resources) N/A (Parcel. No.)

Latitude ~~41.2475~~ 41.42475
Longitude 117.49473
UTM E ____ N ____
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/Clay		0	7	7
3/4 Gravel		7	80	73
Sand/fine gravel		80	138	58

Replaces well log unknown
NAD27
41.42475 3°N
117.49377 0°W

Date started: July 5, 20 13
Date completed: July 6, 20 13

7. Water Level
Static water level: 25 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15-20		4

9. WELL CONSTRUCTION
Depth Drilled 138 Feet Depth Cased 138 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 1/4 Inches	0 Feet	138 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+18	20
6.625	4.06	.316	20	138

Perforations:
Type of perforation Factory Cut
Size of perforation 050
From 98 feet to 138 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 60 ☒ Pumped ☐ Poured
☐ Cement Grout ____ to ____ ☐ Pumped ☐ Poured
☐ Concrete Grout ____ to ____ ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout ____ to ____ ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 60 to 138 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No ____ to ____ ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed ____ By driller performing actual drilling on site or contractor
Date July 15, 2013

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com