STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117372
Permit No.
Basin No. 129

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64733
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Don Moore
MAILING ADDRESS 234 Bonnie Brier Pl
Reno NV 8940 89509

DETAILED ADDRESS AT WELL LOCATION 3005 Inmans rd.
lovelock NV
Subdivision Name: County: Pershing

2. PLS LOCATION NE ¼ NW ¼ 27 Sec 26 N/S 34 E
PERMIT/WAIVER NO. 15-480-06
Issued by Water Resources Current Parcel No.

Latitude 40° 06 04.2 N UTM E ☒ NAD 27
Longitude 118° 08 54.2 W UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Brown Clay			0	97	97
Grey Clay w/Gravel			97	127	20
Grey Stone			127	157	30
Colored Gravels w/stain			157	278	121

RECEIVED 2013 JUL 23 AM 10:2 STATE ENGINEERS OFFICE

Date started: 7-1, 20 13
Date completed: 7-2, 20 13

9. WELL CONSTRUCTION
Depth Drilled: 278 Feet Depth Cased: 278 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	60	Feet
8 1/2	Inches	60	Feet	278	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	278

PERFORATIONS:
Type of perforation: Machine slot
Size of perforation: .080
From 258 Feet To 278 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☒ Sanitary Seal 0 to 60
☒ Neat Cement 0 to 60 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 125' Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
15		2
NAD27		
40.101102°N		
118.148519°N		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Welsco drilling
Contractor
Address P.O. BOX 888 Fallon NV 89406
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 11752
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): #1727
Signed: [signature]
By driller performing actual drilling on site or contractor
Date: 7-18-13

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY