STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 11737B
Permit No.
Basin 0417

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70287

1. OWNER KARMEN BAKER
MAILING ADDRESS 442 LIPPARELLI LN #5
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 469 LIPPARELLI LN
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION SW ¼ NW ¼ Sec 30 T 33N N/S R 57 E
PERMIT/WAIVER No. 006-52C-023
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0618026 [X] NAD 27
N 4508176 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ORIGINAL WELL LOG				
UNKNOWN				
GREY SAND	X	140	170	30
TAN SAND & CLAY	XX	170	200	30
FIRST WATER X	160			

Deepens un-known well log
NAD27
40.717957° N
115.602623° W

Date started: 11-Jul, 20 13
Date completed: 12-Jul, 20 13

9. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	140	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5.625	14.63	.258	116	200

Perforations:
Type of perforation PLASMA CUT
Size of perforation 3/16" X 4", 6 ROWS
From 158 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [ ] Yes [X] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 114 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 58 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AT 195'	35		2 1/2 HOURS
AT 180'	35		
AT 160'	5		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1166
Signed Dale C. Veden (By driller performing actual drilling on site or contractor)
Date 7/12/2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY