

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. **117386**
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **36379**

1. OWNER John Lawrence Moore ADDRESS AT WELL LOCATION 2 MI. N.O. OF BEATTY
MAILING ADDRESS 1305 E. oak Ave NEV. W. side OF 95
Long POC CA 93434 Subdivision Name: none County: MOH

2. LOCATION MW 1/4 NW 1/4 Sec 4 T 11 N/S R 47 E Latitude 37 0054.49N UTM E 16-111-13 NAD 27
PERMIT/WAIVER No. none Longitude 116 43 58.15W NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED New Well Replace Recondition
 Deepen Other

4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------------------|--------------|-----------|------------|------------|
| <u>Sand Gravel & Boulders</u> | | <u>0</u> | <u>50</u> | <u>50</u> |
| <u>White Sand & gravel</u> | | <u>50</u> | <u>40</u> | <u>30</u> |
| <u>Centimental gravel</u> | | <u>80</u> | <u>106</u> | |
| <u>Water Encounter</u> | <u>140'</u> | | | |

DCNR/DWR/SNBO RECEIVED
JUN 27 2013

9. WELL CONSTRUCTION

Depth Drilled 106 Feet Depth Cased 106 Feet

HOLE DIAMETER (BIT SIZE)

| From | To |
|------------------|-------------------------------|
| <u>10</u> Inches | <u>0</u> Feet <u>106</u> Feet |
| _____ Inches | _____ Feet _____ Feet |
| _____ Inches | _____ Feet _____ Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|--------------|------------|
| <u>8 1/2</u> | | <u>CETLOCK</u> | <u>4 1/2</u> | <u>66</u> |
| <u>8 1/2</u> | | <u>1 1/2</u> | <u>66</u> | <u>106</u> |
| <u>8 1/2</u> | | <u>1 1/2</u> | <u>106</u> | <u>8'</u> |

Perforations:

Type of perforation Factory Perf

Size of perforation 4 1/2"

From PERF 66 feet to 106 feet

From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured

Cement Grout to _____ Pumped Poured

Concrete Grout 0 to 50' Pumped Poured

≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 106 to 50 Pumped Poured

Type: 3/8 pea gravel

Bentonite Chips: Yes No to _____ Pumped Poured

Type: Concrete grout poured through track
DISPLACED FROM BOTTOM

7. Water Level

Static water level: 40 feet below land surface

Artesian Flow: no G.P.M. _____ P.S.I. _____

Water Temperature: cool °F

Quality: good

8. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------------|-----------|-------------------------------|--------------|
| <u>AIR LIFT</u> | <u>75</u> | <u>unknown</u> | <u>2 HRS</u> |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Budget Drilling Contractor

Address 11938 E Monroc Ave LV, NV 89110 Contractor

0077029 C23
Nevada contractor's license number

issued by the State Contractor's Board 0077029 C23

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2325

Signed Leanne W. Over
By Driller performing actual drilling on-site or contractor

Date _____