STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**OFFICE USE ONLY**
Log No. 117424
Permit No.
Basin 137B

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

***Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340***

NOTICE OF INTENT NO. 67451

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain, Nevada, 89045

ADDRESS AT WELL LOCATION Round Mountain Pit south ramp
Well Name:DV-13-05

2. LOCATION NW ¼ NW ¼ Sec 30 T 10N N/S R 44 E
PERMIT/WAIVER No. mo1894 *Issued by Water Resources* Parcel No.

Latitude
Longitude
Subdivision Name: N/A
UTM E 492194.747 ☑ NAD 27
N 4283344.6 ☐ NAD 83/WGS 84
*County:* Nye

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☐ Air ☐ Other...

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| dump fill | | 0 | 20 | 20 |
| alluvium | | 20 | 250 | 230 |
| densely welded tuff (type I) | 520 | 250 | 715 | 465 |
| moderately welded tuff (type IX) | | 715 | 775 | 60 |
| poorly welded tuff (type II) | | 775 | 900 | 125 |

NAD27
38.700558 N
117.0697590 W

Date started 10-Jul , 20 13
Date completed 13-Jul , 20 13

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| 900 | 3 | na | 30min |

8. WELL CONSTRUCTION
Depth Drilled 900 Feet Depth Cased 900 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 14.75 | Inches | 0 | Feet | 21 | Feet |
| 6.75 | Inches | 21 | Feet | 900 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8.625 | 22.37 | .25 | 0 | 21 |
| 2.375 | .96 | sch 80 | -2 | 900 |

*Perforations:*
Type of perforation slotted
Size of perforation 0.02
From 100 feet to 900 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Gravel Packed: ☑ Yes ☐ No
From 92 feet to 900 feet

Seal Type:
☑ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
*Static water level* N/A feet below land surface
Artesian flow No G.P.M N/A P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name National EWP Contractor
Address 580 West Silver Street Contractor
Elko Nevada 89801
Nevada contractor's license number issued by the *State Contractor's Board* 00075355
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2457
Signed Wayne [illegible] By driller performing actual drilling on site or contractor
Date 7/20/2013

(Rev. 06/10)

**USE ADDITIONAL SHEETS IF NECESSARY**