

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 17429
 Permit No. _____
 Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **70469**

1. OWNER **Monroe & Myrna Seymore** ADDRESS AT WELL LOCATION **3170 Ether Way**
 MAILING ADDRESS **3170 Ether Way** **Winnemucca, NV**
 Subdivision Name: _____ County: **Humboldt**

2. LOCATION **SW 1/4 SE 1/4 Sec 24 T35N R37E** Latitude **40.89040'** UTM E NAD 27
 PERMIT/WAIVER NO. **N/A** **014-103-20** Longitude **117.75999'** N NAD 83/WGS 84
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Course gravel		155	170	15
rock ledge		170	175	5
course gravel	X	175	205	30
Clay		205	208	3
course sand & Gravel	X	208	235	27
cobles & gravel	X	235	255	20
<i>deeper unknown well log</i>				
<i>N4D25</i>				
<i>40.89040' N</i>				
<i>117.75999' W</i>				

Date started: **August 6, 20 13**
 Date completed: **August 7, 20 13**

9. WELL CONSTRUCTION

Depth Drilled **255** Feet Depth Cased **255** Feet

HOLE DIAMETER (BIT SIZE)
 From **6 1/4** Inches To **255** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10	.188	155	255

Perforations:
 Type of perforation **Factory Cut**
 Size of perforation **3/32 X 4**

From **215** feet to **255** feet
 From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement Exist to _____ Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Natural Gravel Pack: Yes No _____ to _____ Pumped Poured
 Type: _____
 Bentonite Chips: Yes No _____ to _____ Pumped Poured
 Type: _____

7. Water Level

Static water level: **155** feet below land surface
 Artesian Flow: **N/A** G.P.M. **N/A** P.S.I.
 Water Temperature: **Cool** °F
 Quality: **Good**

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
15-20		4	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Fred Anderson Drilling, Inc.**
(CONTRACTOR)

Address **10760 S. Grass Valley Road**
(CONTRACTOR)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board **021467**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2083**

Signed *Chris [Signature]*
 By driller performing actual drilling on site or contractor
 Date **August 8, 2013**