STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117437
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37674

1. OWNER Lamb Charleston LLC% A Sneider
MAILING ADDRESS 201 S. Figuero St
Los Angeles, CA 90012-2543

ADDRESS AT WELL LOCATION 1275 S. Lamb- Sunrise Manor
EW-9

2. LOCATION NW¼ NW ¼ Sec 5 T 21S N/S R 62 E
PERMIT/WAIVER No. 161-05-110-003
Issued by Water Resources — Parcel No.

Latitude 36 09'27.96"N
Longitude 115 04'51.95"W
UTM E
N
☐ NAD 27
☑ NAD 83/WGS 84
Subdivision Name:
County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	5	5
Sandy Silt		5	13	8
Sandy Clay		13	16	3
Sandy Silt		16	22	6
Clayey Sand		22	27	5
Sandy Clay		27	35	8
Clayey Sand		35	38	3
Sandy Clay		38	45	7

DCNR/DWR/SNBO
RECEIVED
JUN 28 2013

Date started 6-Jun , 20 13
Date completed 6-Jun , 20 13

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	45	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		Sch 40	0	45

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02
From 15 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 11
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 13 feet to 45 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling L.P. (Contractor)
Address 4590 Copper Sage St (Contractor)
Las Vegas, NV 89115
Nevada contractor's license number issued by the *State Contractor's Board* C23 0073966
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2381
Signed (By driller performing actual drilling on site or contractor)
Date 6-28-13

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY

36.15776
-115.0810972