

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117455
Permit No. _____
Basin No. 212

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37061
WELL NAME (if applicable): MW-10

1. OWNER/CLIENT NAME Jose Rios - 7-Elven Dr DETAILED ADDRESS AT WELL LOCATION 7265 S. Las Vegas Blvd
MAILING ADDRESS Po Box 711 L.V. NV.
Dallas TX 75221 Subdivision Name: _____ County: Clark

2. PLS LOCATION SE 1/4 SE 1/4 5 Sec 22 T/S 61 E Latitude 36° 03' 26.99" N UTM E NAD 27
PERMIT/WAIVER NO. 17705801038 Longitude 115° 10' 23.31" W UTM W NAD 83/WGS 84
Issued by Water Resources Current Parcel No.

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Asphalt Base			0	5	5'
Silty Sand			5	1.5	1'
silty clay			1.5	25	23.5
caliche			25	30	5
Sandy clay			30	46	16'
silty sand		76	46	73	29'
sandy			73	90	15'
			90	131	41

9. WELL CONSTRUCTION

Depth Drilled: 131 Feet Depth Cased: 131 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10.25</u>	<u>0</u>	<u>131</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>2.118</u>	<u>.188</u>	<u>.5</u>	<u>91</u>
<u>4</u>	<u>2.118</u>	<u>.188</u>	<u>91</u>	<u>131</u>

PERFORATIONS:

Type of perforation: Factory
Size of perforation: 020

From 91 Feet To 131 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

ANNULAR MATERIALS

Sanitary Seal 86' to 89' Pumped Poured
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips 86' to 89' Pumped Poured
 Bentonite Grout .5" to 86' Pumped Poured
 15 % 20 % Other, explain: _____
 Gravel Pack [> 0.2 in.] _____ to _____ Pumped Poured
 Sand Pack [< 0.2 in.] 89' to 131' Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 6-2- , 20 13
Date completed: 6-3 , 20 13

7. WATER QUALITIES
Static water level: 79 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP Contractor
Address 152 Laguna Landing D. Henderson NV 89002 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2492
Signed: Russ L. Ewert
By driller performing actual drilling on site or contractor
Date: _____

36,0574972
-115,1731416