

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117456
Permit No. _____
Basin No. 212

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37062
WELL NAME (if applicable): S2 MW-7

1. OWNER/CLIENT NAME Jose Rios - 7-Eleven Inc DETAILED ADDRESS AT WELL LOCATION 1100 S. LAS VEGAS BLVD
MAILING ADDRESS PO Box 711 LAS VEGAS, NV
Dallas Tx 75221 Subdivision Name: _____ County: Clark

2. PLS LOCATION NE 1/4 NW 1/4 03 Sec 21 N/S 61 E Latitude 36.158667 UTM E NAD 27
PERMIT/WAIVER NO. 16-03-199-017 Longitude 115.147554 UTM N NAD 83/WGS 84
Issued by Water Resources Current Parcel No.

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor Auger Rotary RVC
 Mining / Dewater Com / Ind Stock Air Mud Sonic
 Test / Other Mun / QM Rec Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Asphalt			0	0.5	0.5
Road Base			0.5	2	1.5
Caliche			2	5	3
Sandy silt			5	10	5
Sandy gravel			10	21	11
silty clay			21	23	2

9. WELL CONSTRUCTION
Depth Drilled: 22.8 Feet Depth Cased: 22.47 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10.25</u>	0			<u>22.8</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>2.118</u>	<u>.188</u>	<u>6"</u>	<u>7.47</u>
<u>4"</u>	<u>2.118</u>	<u>.188</u>	<u>7.47</u>	<u>22.47</u>

PERFORATIONS:

Type of perforation: factory
Size of perforation: 020
From 7.8 Feet To 22.8 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

ANNULAR MATERIALS

Sanitary Seal 8" to 2' Pumped Poured
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips 3' to 6' Pumped Poured
 Bentonite Grout 2' to 3' Pumped Poured
 15 % 20 % Other, explain: _____
 Gravel Pack [> 0.2 in.] _____ to 4' Pumped Poured
 Sand Pack [< 0.2 in.] 6' to 22.8' Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 6-17- 20 13
Date completed: 6-17- 20 13

7. WATER QUALITIES
Static water level: 6 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 74.2 ° Fahrenheit
Water Quality: _____

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Samuel Sapien Contractor
Address National EWP Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2497-
Signed: Samuel Sapien
By driller performing actual drilling on site or contractor.
Date: 6-18-13