STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117480
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70702

1. OWNER ARNOLD BECK CONSTRUCTION INC
MAILING ADDRESS 247 GREENCREST DR
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 861 DRY CREEK TRAIL
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION NW ¼ NW ¼ Sec 33 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09Q-009 (Issued by Water Resources) Parcel No.

Latitude
Longitude
UTM E 11T 0602113 ☒ NAD 27
N 4516387 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL STRIPPED				
SAND & GRAVEL w/		0		
BOULDERS			50	50
GRAY TAN SAND & CLAY		50	100	50
GRAY BLACK CLAY		100	190	90
VOLCANIC TUFT	X	190	250	60
FINE GRAVEL w/ BLACK SAND	XX	250	260	10
1ST WATER X	180			
2ND WATER XX	250			
NAD27				
40.440390 N				
115.796042 W				

Date started: 7-Aug, 20 13
Date completed: 8-Aug, 20 13

7. Water Level
Static water level: 93 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 70 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AT 260'	80		1 1/2 HOURS
AT 240'	70		
AT 160'	50		
AT 120'	15		

9. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	60
6.625	4	SDR 21 .316	60	260

Perforations:
Type of perforation FACTORY SLOTS
Size of perforation 0.025 6 ROWS
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 4 to 25 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 55 to 260 ☐ Pumped ☒ Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: ☒ Yes ☐ No 25 to 55 ☐ Pumped ☒ Poured
Type: 3/8" BENTONITE CHIPS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed (By driller performing actual drilling on site or contractor)
Date 8/9/2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY