STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117486
Permit No.
Basin 212

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

***Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340***

NOTICE OF INTENT NO. 37663

1. OWNER CK 3285 S. Nellis Blvd LLC % L Shapiro
MAILING ADDRESS 10300 W. Charleston Blvd #13-156
Las Vegas, NV 89135-1037

ADDRESS AT WELL LOCATION 3285 S. Nellis Blvd

2. LOCATION SE ¼ SE ¼ Sec 8 T 21S N/S R 62 E
PERMIT/WAIVER No. 161-08-810-062
*Issued by Water Resources* Parcel No.

Latitude 36.129978
Longitude 115.065755
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: *County:* Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill | | 0 | 1 | 1 |
| Clayey Silt | | 1 | 8 | 7 |
| Sandy Silt | | 8 | 15 | 7 |
| Sandy Clay | | 15 | 19 | 4 |
| Sandy Silt | | 19 | 27 | 8 |

DCNR/DWR/SNBO
RECEIVED
JUN 28 2013

Date started 14-May , 20 13
Date completed 14-May , 20 13

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |
| | | .5 |

8. *WELL CONSTRUCTION*
Depth Drilled 27 Feet Depth Cased 25 Feet

*HOLE DIAMETER (BIT SIZE)*

| | | From | | To | |
|---|---|---|---|---|---|
| 8 | Inches | 0 | Feet | 27 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

*CASING SCHEDULE*

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | | Sch 40 | 0 | 25 |
| | | | | |
| | | | | |

*Perforations:*
Type of perforation Factory Slotted
Size of perforation 0.02
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 3
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 3 feet to 27 feet

9. *WATER LEVEL*
*Static water level* 16 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling L.P.
Contractor
Address 4590 Copper Sage St
Contractor
Las Vegas, NV 89115
Nevada contractor's license number issued by the *State Contractor's Board* C23 0073966
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2381
Signed
By driller performing actual drilling on site or contractor
Date 6-11-13

0883

(Rev. 06/10)
**USE ADDITIONAL SHEETS IF NECESSARY**

36.1300051
115.064924 -NAD27