STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117497
Permit No.
Basin 087

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70577

1. OWNER Tony Maruri
MAILING ADDRESS 15490 Fawn Ln
Reno NV 89511

ADDRESS AT WELL LOCATION 15494 Fawn Ln
Reno, NV 89511
Subdivision Name: County: Washoe

2. LOCATION SW ¼ NW ¼ Sec 36 T 18 / R 19 E
PERMIT/WAIVER NO. DOM13-33 (Issued by Water Resources) 150-222-01 (Parcel. No.)

Latitude 39.382331 Longitude -119.805308
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite		198	230	32
Softer with some clay		230	245	15
Granite		245	260	15
Softer		260	265	5
Brown Clay		265	267	2
Softer DG, Sand & Brown Clay	x	267	275	8
Granite		275	353	78
Larger Sands, Volcanics & Sandy Brown Clay	x	353	370	17

WL130035

Removed 5" liner to deepen the well.

NAD27
39.382421°N
119.804287°W

Date started: 6/24, 20 13
Date completed: 6/26, 20 13

7. Water Level
Static water level: 166 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: Cool °F
Quality: Not Tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	30	4

Deepen well logs #14883: 33252

9. WELL CONSTRUCTION
Depth Drilled 370 Feet Depth Cased 370 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 7/8 Inches	198 Feet	370 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	110	390

Perforations:
Type of perforation Factory Cut
Size of perforation 3 x 3/32
From 370 feet to 350 feet
From 270 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☒ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bennett
By driller performing actual drilling on site or contractor
Date 7/15/13

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com