STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117559
Permit No.
Basin 209

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35674

1. OWNER Remi Asindraza
MAILING ADDRESS PO Box 554 Alamo NV 89001
ADDRESS AT WELL LOCATION 1667 Ash tree road Alamo NV
Subdivision Name: 0 County: Lincoln

2. LOCATION SE¼ NW¼ Sec 32 T 6 N (S) R 61 E
PERMIT/WAIVER No. 011-200-26 Issued by Water Resources Parcel No.
Latitude N37°23.196 Longitude W115 09.986
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cleaned this 8" well				
to 84' Hard Bottom				
Installed 6" PVC liner				
It appears to Have 50'				
surface seal				

Date started: 3-5-2013 , 20
Date completed: 3-6-2013 , 20

9. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased 84 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6½	PVC	Sch 40	0	84

Perforations:
Type of perforation Saw cut
Size of perforation 1/8" x 3"
From 50 feet to 84 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 13 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: poor

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		2

DCNR/DWR/SNBC RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC61 Box 54 Hiko NV 89017 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on-site or contractor)
Date 3-7-2013

(Rev. 05-06)

MAR 20 2013

USE ADDITIONAL SHEETS IF NECESSARY

37.3866388
115.1655824

(NSPO 3-08)

(O) 627