STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 117607
Permit No.
Basin 137A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1 OWNER Nye Co Public works
MAILING ADDRESS 250 N Highway 160 #2
Pahrump NV 89060

NOTICE OF INTENT NO.
ADDRESS AT WELL LOCATION North end of Gold Street
Subdivision Name: County:

2 LOCATION SE ¼ NW ¼ Sec 20 T 8N N/S R 44 E
PERMIT/WAIVER No. R-740
Issued by Water Resources Parcel No.

Latitude 117 4' 24"
Longitude 38 3' 7"
UTM E 494075 E ☒ NAD 27
N 4265157 N ☐ NAD 83/WGS 84

3 TYPE OF WELL
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

Is this well being plugged because a replacement well was drilled?
If yes, what is replacement well NOI?

Is there an existing well log? Yes
If yes, what is NDWR well log #?

4 EXISTING WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	32	.332	+2	460

Existing Perforations:
Type of perforation Machine slots
Size of perforation .080

From	feet to	feet
240	460	

5 WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

6 Additional Notes or Comments

453 set 5 BBL 30% Grout
453 to 399 - 30 sx hole plug
399 to 396 neat cement

NAD27
38.536664°N
117.067982°W

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? ☐ yes ☒ no
If well was not cleaned out to total depth, please explain why:
CASING egged bottom 20' feet
Was the well contaminated? ☐ yes ☐ no
Was the casing pulled? ☐ yes ☒ no
Was the casing over drilled? ☐ yes ☒ no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used:

From	feet to	feet	Number of perfs per linear foot

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used		
453		453		☒ Pumped	☐ Poured
453	54	399		☒ Pumped	☐ Poured
				☐ Pumped	☐ Poured
				☐ Pumped	☐ Poured
				☐ Pumped	☐ Poured
				☐ Pumped	☐ Poured

Neat Cement Fluid Weight lbs/gal
Bentonite Grout 5 BBL 30 % bentonite
Date Started 7-22-13
Date Completed 8-1-13

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Welsco Corp
Contractor
Address P.O. Box 888
Contractor
Fallon NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1727
Signed [signature]
By driller performing actual drilling on site or contractor
Date 8-1-13

RECEIVED 2013 AUG -7 AM 10:14 STATE ENGINEER'S OFFICE

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

684-2810