

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT**

**OFFICE USE ONLY**

Log No. 117610

Permit No. \_\_\_\_\_

Basin 105

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

1 OWNER BENTLY NEVADA CORP Douglas County ADDRESS AT WELL LOCATION 2103 Heybourne Rd. NOTICE OF INTENT NO. 69618 ✓  
 MAILING ADDRESS 1617 WATER ST Airport NE MINDEN HEYBORNE RD AND  
MINDEN, NV 89423 AIRPORT RD MINDEN, NV 89423

2 LOCATION NW ¼ SE ¼ Sec 8 T 13N N/S R 20 E Latitude 39.00321°N UTM E  NAD 27  
 PERMIT/WAIVER No. 1320-08-002-007 Longitude 119.76028°W N  NAD 83/WGS 84

3 TYPE OF WELL  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 Is this well being plugged because a replacement well was drilled? NO  
 If yes, what is replacement well NOI? \_\_\_\_\_  
 Is there an existing well log? YES  
 If yes, what is NDWR well log #? 32154

4 EXISTING WELL CONSTRUCTION

Depth Drilled 72 Feet Depth Cased 72 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	72

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth?  yes  no  
 If well was not cleaned out to total depth, please explain why: \_\_\_\_\_

Was the well contaminated?  yes  no  
 Was the casing pulled?  yes  no  
 Was the casing over drilled?  yes  no  
 If casing was left in place, please show where additional perforations were made:  
 Additional Perforations: \_\_\_\_\_

Existing Perforations:

Type of perforation	Size of perforation	From	To
FACTORY SLOT	0.032	42 feet	72 feet

Type of perforator used: MILLS KNIFE

From	To	Number of perfs per linear foot
35 feet	45 feet	4

5 WATER LEVEL

Static water level 46 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature N/A °F Quality N/A

8 WELL PLUGGING MATERIALS

From	To	Material Used	Pumped	Poured
0 feet	72 feet	NEAT CEMENT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments

PLACED 2" TREEMIE TO BOTTOM AND PUMPED FULL OF NEAT CEMENT.

39.003302°N NAD27  
119.759269°W  
Plugs well log # 32154

STATE ENGINEERS OFFICE  
 1012 OCT 29 AM 11:01

Neat Cement Fluid Weight 94/4 lbs/gal  
 Bentonite Grout \_\_\_\_\_ % bentonite  
 Date Started 10/17/2012  
 Date Completed 10/17/2012

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING AND PUMP SYSTEM INC.  
 Contractor  
 Address 20 KIT KAT DRIVE  
 Contractor  
CARSON CITY, NV 89706

Nevada contractor's license number issued by the State Contractor's Board 0055548  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10/19/2012

USE ADDITIONAL SHEETS IF NECESSARY

Form 06-09