

Lot #2

OTUS

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 117715  
Permit No.  
Basin 207

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Forest Man Ranch, Inc  
MAILING ADDRESS 1900 Colorado Street  
Boulder City NV 89005

ADDRESS AT WELL LOCATION Forest Man Ranch  
Sunnyside NV  
Subdivision Name: Forest Man acres County: NYE

NOTICE OF INTENT NO. 67919

2. LOCATION NW 1/4 Sec 18 T 6 N R 61 E  
PERMIT/WAIVER No. 013-811-02

Latitude N38°22'6.87" UTM E  NAD 27  
Longitude W115°10'17.5" N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
clay sand - boulders		0	61	61
clay gravel - boulders	X	61	102	41
clay		102	113	11
gravel - clay	X	113	120	7
Hard Clay		120	130	10
7' of 8 1/2" steel casing was grouted over 6" PVC for well head protection				

9. WELL CONSTRUCTION  
Depth Drilled 130 Feet Depth Cased 130 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 130  
Inches 0 Feet 130  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>130</u>

Perforations:  
Type of perforation grout cut  
Size of perforation 1/8" x 3"  
From 60 feet to 130 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement 0 to 50  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 50 to 130  Pumped  Poured  
Type: Red manos  
Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

7. Water Level  
Static water level: 25 feet below land surface  
Artesian Flow: 0 G.P.M.  P.S.I.  
Water Temperature: calc °F  
Quality: Fair

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Dennis Drilling and Pumps Contractor  
Address HC 61 Box 54 Hiko NV 89017 Contractor  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 0028966  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
Signed Mike Dan  
By driller performing actual drilling on-site or contractor  
Date 11-15-2012

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>	<u>2</u>	