STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117720
Permit No.
Basin 057

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67137

1. OWNER GoFer Market
MAILING ADDRESS 2000 Kirman Ave. Reno, NV

ADDRESS AT WELL LOCATION Facility ID: 4-000502 16D
4600 N Virginia Street Reno, NV
Subdivision Name: County: Washoe

2. LOCATION NW ¼ SW ¼ Sec 26 T 20N N/S R 19 E
PERMIT/WAIVER No. 003-091-18
Issued by Water Resources Parcel No.

Latitude 39.570139
Longitude -119.824952
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty clay with loose fine gravel		0	25	25
Silty clay with course to fine sands		25	30	5
Boulders with clay/silt		30	45	15
Clay, little to no gravel		45	53	8
Clay with cobbles and silty sand		53	70	17
Clay, little cobbles		70	80	10
Boulders with silty clay		80	90	10

Date started: 3-Feb , 20 12
Date completed: 4-Feb , 20 12

9. WELL CONSTRUCTION
Depth Drilled 90 Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8 1/4	Inches	0	Feet	90	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Sch 40	0	90

Perforations:
Type of perforation Slot
Size of perforation .010
From 70 feet to 90 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 3 to 63 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 68 to 90 ☐ Pumped ☒ Poured
Type: 2/12 Sand
Bentonite Chips: ☒ Yes ☐ No 63 to 68 ☐ Pumped ☒ Poured
Type: 3/8 Chips

7. Water Level
Static water level: 50 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling, L.P. (Contractor)
Address 3632 Omec Circle (Contractor)
Rancho Cordova, CA 95742
Nevada contractor's license number issued by the *State Contractor's Board* 0073966
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2425
Signed (By driller performing actual drilling on site or contractor)
Date 3/10/2012

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

NAD 27 39.570229°N -119.823926°W