

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 117774
Permit No. 36150
Basin 105

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 68338 ✓

1 OWNER Douglas county Public Works
MAILING ADDRESS 1120 Airport Road, Building F2
Minden, NV, 89423

ADDRESS AT WELL LOCATION At the south end of Nowlan Lane
off Johnson Lane near Minden, NV.
Subdivision Name: _____ County: Douglas

2 LOCATION SE ¼ NE ¼ Sec 5 T 13N N/S R 20 E
PERMIT/WAIVER No. 36150
Issued by Water Resources Parcel No.

Latitude 39 01.295N UTM E NAD 27
Longitude 119 45.257W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? _____
If yes, what is replacement well NOI? _____
Is there an existing well log? yes
If yes, what is NDWR well log #? 22313

4 EXISTING WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	n/a	.250	1	300

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:

Existing Perforations:				
From	Type of perforation	Size of perforation	feet to	feet
	factory mill slot	3/32 X 3"	300	
From 60				
From				

Type of perforator used:					Mills Knife	
From	feet to	feet	Number of perfs per linear foot			
From 60	feet to	0	feet	Number of perfs per linear foot	6	
From	feet to		feet	Number of perfs per linear foot		
From	feet to		feet	Number of perfs per linear foot		
From	feet to		feet	Number of perfs per linear foot		
From	feet to		feet	Number of perfs per linear foot		
From	feet to		feet	Number of perfs per linear foot		

5 WATER LEVEL
Static water level 10.9 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ ° F Quality _____

8 WELL PLUGGING MATERIALS

From		feet to		feet		Material Used	
From 300	feet to	0	feet	neat cement	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
From	feet to		feet		<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
From	feet to		feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
From	feet to		feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
From	feet to		feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
From	feet to		feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	

6 Additional Notes or Comments

Removed 105' of 3" drop pipe with 20hp pump. Measured static water level at 10.9' and depth of well at 294'. Bailed debris from well to a depth of 298' where we seemed to hit a hard bottom. We then installed 10" mills knife and cut 6 rows per foot from 60' back to surfac. We installed 2" tremmie pipe to 290'. We had neat cement delivered the folowing day and pumped in 9.5 yards of neat cement. The casing was cut off 2' bgs.

Neat Cement Fluid Weight 14.4 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 10/4/2012
Date Completed 10/5/2012

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Carson Pump, LLC Contractor
Address P.O. Box 20159 Contractor
Carson City, NV, 89721
Nevada contractor's license number _____
issued by the State Contractor's Board 39920
Nevada driller's license number issued by the _____
Division of Water Resources, the on-site driller 2265
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 10/31/2012

(Rev 05/08)

USE ADDITIONAL SHEETS IF NECESSARY

NAD27 39.021675°N, 119.753272°W