STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117789
Permit No.
Basin 078

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68629

1. OWNER C - Punch
MAILING ADDRESS 1100 1/2 Fuss Rd.
Lovelock, NV 89419

ADDRESS AT WELL LOCATION Granite Springs Valley
Lovelock, NV 89419
Subdivision Name: County: Pershing

2. LOCATION NW ¼ SE ¼ Sec 9 T 26N N/S R 27 E
PERMIT/WAIVER No. Issued by Water Resources
Parcel No.

Latitude 40.13598 N
Longitude -118.95488 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	4	4
Clay		4	12	8
Sand w/s Gravel		12	18	6
Clay		18	49	31
Fine Sand		49	67	18
Sand		67	84	17
Sand w/s Gravel		84	103	19
Gravel w/s gravel		103	209	106
Sand	XX	209	220	11

RECEIVED 2012 MAY -9 AM 11:31 STATE ENGINEERS OFFICE

Date started: 9-Apr , 20 12
Date completed: 12-Apr , 20 12

7. *Water Level*
Static water level: 120 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. *WELL CONSTRUCTION*
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	19
6.625	4.0	.316	19	220

Perforations:
Type of perforation Saw Cut
Size of perforation 0.125
From 215 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 15 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 15 to 65 ☒ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 65 to 220 ☐ Pumped ☒ Poured
Type: 3/8" Well Gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2307
Signed (By driller performing actual drilling on site or contractor)
Date 5/4/2012

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

NAD27 40.136073°N, 118.953883°W