STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117830
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69168

1. OWNER Dave Ott
MAILING ADDRESS 6035 Lakeview Dr.
Fallon, NV 89406

ADDRESS AT WELL LOCATION 6035 Lakeview Dr.
Fallon, NV 89407
Subdivision Name: County: Churchill

2. LOCATION NE ¼ SE ¼ Sec 18 T 19N N/S R 28 E
PERMIT/WAIVER No. 1008-113-32
Issued by Water Resources Parcel No.

Latitude 39.500853 N
Longitude -118.87670 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	12	12
Brown Clay		12	26	14
Fine Brown Sand		26	34	8
Brown Sand	X	34	60	26

replaced unknown well log
unknown well log plugged by
well log #117831

Date started: 29-Jun, 20 12
Date completed: 29-Jun, 20 12

9. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	60	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	19
6	12.92	.188	19	60

Perforations:
Type of perforation Saw Cut
Size of perforation 1/8"
From 56 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 55 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 55 to 60 ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 6 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2307
Signed (By driller performing actual drilling on site or contractor)
Date 7/5/2012

RECEIVED 2012 SEP -4 AM 11:27 STATE ENGINEER'S OFFICE

(Rev. 05-05)
USE ADDITIONAL SHEETS IF NECESSARY

NAD27 39.508614°N, 118.875711°W