

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 117842  
Permit No. \_\_\_\_\_  
Basin 087

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69060

1. OWNER 7-Eleven INC. ADDRESS AT WELL LOCATION 1680 Silverada Blvd.  
MAILING ADDRESS P.O. Box 711 Reno NV 89572  
Dallas TX 75221 Subdivision Name: N/A County: Washoe  
2. LOCATION SE 1/4 NW 1/4 Sec 6 T 19 N R 20 E Latitude N 39.54454° UTM E  NAD 27  
PERMIT/WAIVER No. 4-000379 1008-073-01 Longitude W 119.78237° N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  Air  Other  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Other

6. LITHOLOGIC LOG MW 9

Material	Water Strata	From	To	Thick-ness
<u>A/C</u>		<u>0</u>	<u>5"</u>	<u>5"</u>
<u>Air Knife to 5'</u>				
<u>brown clayey sand (sc)</u>		<u>5"</u>	<u>5'</u>	<u>4'7"</u>
<u>Grey well graded gravel</u>				
<u>(G.W.) w/ sand dry</u>		<u>5'</u>	<u>25'</u>	<u>20'</u>
<u>brown well graded sand</u>		<u>25'</u>	<u>30'</u>	<u>5'</u>
<u>(S.W.) moist</u>		<u>25'</u>	<u>35'</u>	<u>10'</u>
<u>brown silty gravel (GM)</u>	<u>37</u>	<u>35'</u>	<u>45'</u>	<u>10'</u>
<u>w/ sand sat.</u>				
<u>brown clayey sand (SC)</u>		<u>45</u>	<u>46</u>	<u>1</u>
<u>SAT.</u>				

9. WELL CONSTRUCTION  
Depth Drilled 46 Feet Depth Cased 45 1/2 Feet  
HOLE DIAMETER (BIT SIZE)  
From 8 Inches To 0 Feet  
Inches 46 Feet  
Inches \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>sch 40</u>	<u>45 1/2</u>	<u>1/2</u>

Perforations:  
Type of perforation 0.020  
Size of perforation slotted screened  
From 45 feet to 25 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement 22 to 1  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 1 to 0  Pumped  Poured  
 20% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
Gravel Pack:  Yes  No 45 1/2 to 24  Pumped  Poured  
Type: Cemex Lap's Lustre #3  
Bentonite Chips:  Yes  No 24 to 22  Pumped  Poured  
Type: Pure Gold med. chips

Date started: 12/5/12 Date completed: 12/6/12

7. Water Level  
Static water level: 37' feet below land surface  
Artesian Flow: NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. N/A WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Dale Lehman Contractor  
Address 520 Edison Way Contractor  
Reno NV 89502  
Nevada contractor's license number CASCADE  
issued by the State Contractor's Board Drilling # 73966  
Nevada driller's license number issued by the  
Division of Water Resources, the on-site driller M-1976  
Signed Dale Lehman  
By driller performing actual drilling on site or contractor  
Date 12/12/12

(Rev. 05-08) USE ADDITIONAL SHEETS IF NECESSARY

NAD27 39.544629°N, 119.781347°W