

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 117854
Permit No. _____
Basin 069

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1 W. R. HANSEN 66101
7150 DUTCH FLAT ROAD WINNEMUCCA, NV 7150 DUTCH FLAT ROAD WINNEMUCCA
NV.89445
HUMBOLDT

2 NW NW 20 38N 39
006-461-02 N41 09 36" 48.6
W117 36 58"

3 TYPE OF WELL Is this well being plugged because a replacement well was drilled? YES Is there an existing well log? NO
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
If yes, what is replacement well NO? 66100 If yes, what is NDWR well log #? _____

4 Depth Drilled 150 Feet Depth Cased 150 Feet
120 Feet 120 Feet

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	<u>17.02</u>	1/4	+1.5	150

7 Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____
Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made: _____

Type of perforation	Size of perforation	UNKNOWN
From _____	feet to _____	feet
From _____	feet to _____	feet
From _____	feet to _____	feet
From _____	feet to _____	feet
From _____	feet to _____	feet

Type of perforator used: DUPONT
From 20 feet to 150 feet Number of perfs per linear foot 2
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

5 Artesian flow x 70 feet below land surface
Water temperature 58 °F G.P.M. _____ P.S.I. _____
Quality POOR

From	feet to	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From <u>30</u>	feet to <u>150</u>	feet <u>GROUT</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From <u>20</u>	feet to <u>30</u>	feet <u>BENTONITE CHIPS</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
From <u>0</u>	feet to <u>20</u>	feet <u>NEAT CEMENT</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet _____	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet _____	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet _____	<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
Plugs unknown well log replaced by log 117854
117.615151
41.1635990
117.615151

Neat Cement Fluid Weight lbs/gal
Bentonite Grout 20 % bentonite
8/8/2013
8/11/2013

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name HANSEN DRILLING Contractor
Address 7150 DUTCH FLAT ROAD Contractor
WINNEMUCCA, NV. 89445
Nevada contractor's license number issued by the 0074945
Nevada driller's license number issued by the Division of Water Resources, the 2416
W. R. Hansen
By Driller performing actual drilling on site or contractor