STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117860
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69909

1. OWNER Alma Reeder
MAILING ADDRESS 1775 Kristi GU NV 89460
ADDRESS AT WELL LOCATION 1775 Kristi GU NV 89460
Subdivision Name: County: Douglas

2. LOCATION NE ¼ NE ¼ Sec 26 T 13 N/S R 20 E
PERMIT/WAIVER No. DOM13-46 1320-26-001-044
Issued by Water Resources Parcel No.
Latitude 38° 58.042 UTM E ☐ NAD 27
Longitude 119 42.018 N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	18	18
Small Gravel		18	22	4
Multi Color Chip Rock		22	x	
& Sand		x	43	21
Med-lrg Chip Rock		43	x	
Brown Clay		x	64	21
Dense Brow Gritty Clay		64	76	12
Sand & Chip Rock		76	132	56
Med Sand & Chip Rock		132	160	28
Med Sand & Small		160	x	
Gravel Some brown		x	230	
Clay				70
Replaces unknown well log				
NAD27				
38.968292°N				
119.699292°W				

Date started: 7-23-13, 20
Date completed: 7-25-13, 20

7. Water Level
Static water level: 98 feet below land surface
Artesian Flow: N/A G.P.M. 20 P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
185	20	3

9. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	230	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	10
6 5/8		SDR 21	10	230

Perforations:
Type of perforation Factory
Size of perforation 3/32
From 190 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 52 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 52 to 230 ☐ Pumped ☐ Poured
Type: 3/8 Round rock
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO INC.
P.O. Box 1255
Address Carson City, NV 89702
Contractor

Nevada contractor's license number issued by the State Contractor's Board 46498A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2321

Signed C. Robinson
By driller performing actual drilling on-site or contractor
Date 7-30-13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627