STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117892
Permit No.
Basin 876

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69262

1. OWNER Richard Bode
MAILING ADDRESS P.O. Box 851
Fernley, NV 89408

ADDRESS AT WELL LOCATION 4220 Farm District Rd
Fernley, NV 89408
Subdivision Name: County: Lyon

2. LOCATION NE ¼ SE ¼ Sec 23 T 20N N/S R 25 E
PERMIT/WAIVER No. 021-351-07
Issued by Water Resources Parcel No.

Latitude 39.58377 N
Longitude -119.13603 W
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay w/s Sand		0	11	11
Clay w/s Gravel		11	18	7
Rock		18	64	46
Clay and Rock		64	72	8
Gravel		72	86	14
Clay w/s Gravel		86	102	16
Clay		102	121	19
Clay w/s Rock		121	134	13
Sand w/s Gravel	XX	134	140	6

Date started: 22-Aug, 20 12
Date completed: 22-Aug, 20 12

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	19
6.625	4.0	.316	19	140

Perforations:
Type of perforation Saw Cut
Size of perforation 0.125
From 135 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 100 to 0 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 140 to 100 ☐ Pumped ☒ Poured
Type: 3/8" pea gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 84 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2307
Signed (By driller performing actual drilling on site or contractor)
Date 8/24/2012

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

NAD 27 39.583770°N, 119.136030°W