STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 117898
Permit No.
Basin 069

NOTICE OF INTENT NO. 68891

1. OWNER Scott & Stephanie Huesboe
MAILING ADDRESS PO Box 72, Paradise Valley, NV

ADDRESS AT WELL LOCATION Cottonwood Futures LLC
Subdivision Name: County: Humboldt

2. LOCATION NE¼NE¼ Sec11T41N/ R39E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 004-475-01 (Parcel. No.)

Latitude 41°27.253 Longitude 117°32.427
UTM E N ☐ NAD 27 ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/Clay		0	3	3
Course sand/Fine gravel		3	40	37
Cobbles/gravel		40	55	15
Clay		55	80	25
sand - fine	X	80	115	35
Clay		115	130	15
Sand/fine gravel	X	130	160	30
Clay		160	180	20

Date started: April 16, 20 12
Date completed: April 18, 20 12

RECEIVED 2012 MAY 11 AM 10:49 STATE ENGINEERS OFFICE

7. Water Level
Static water level: 50 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		5

9. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4	Inches	0 Feet	180 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	20
6.625	4.06	.316	20	180

Perforations:
Type of perforation Factory Cut Slots
Size of perforation 050
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 180 ☒ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling Inc
By driller performing actual drilling on site of contractor
Date May 8, 2012

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

NAD27 41.454320°N, 117.5394889W