STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117914
Permit No.
Basin Ø28

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69784

1. OWNER Allied Gold Corp.
MAILING ADDRESS 9790 Gateway Dr. Ste 200 Reno NV 89521

ADDRESS AT WELL LOCATION Sulfur to Imlay Rd. KP-DH-06
Subdivision Name: County: Pershing

2. LOCATION SW ¼ NW ¼ Sec 34 T 35 N R 29 E
PERMIT/WAIVER No. MO 1853
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 354458.44 ☐ NAD 27
N 4525795.42 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Silty Some Clay		0	6	6
Sand Silty Fine grain		6	15	9
Sand Some Silt gravel		15	17	2
Clay Some sand hard		17	105	88

Date started: 10-15, 20 12
Date completed: 10-26, 20 12

9. WELL CONSTRUCTION
Depth Drilled 105 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	8	Feet	105	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch 40	+2	80

Perforations:
Type of perforation Factory mill slot
Size of perforation
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 20 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 78 to 105 ☐ Pumped ☐ Poured
Type: 8-16 Silica Sand
Bentonite Chips: ☒ Yes ☐ No 78 to 75 ☐ Pumped ☒ Poured
Type: 3/8 chips

7. Water Level
Static water level: 10.9 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name National EWP (Contractor)
Address 580 W. Silver St. (Contractor)
Elko NV 89501
Nevada contractor's license number issued by the State Contractor's Board 0075355
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2111
Signed (By driller performing actual drilling on-site or contractor)
Date 10-28-12

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) NAD27 40.865000°N, 118.125990°W

(O) 627