

RECEIVED  
 NOV - 9 AM 10  
 STATE ENGINEERS OF

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 117920  
 Permit No. \_\_\_\_\_  
 Basin 028

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69787

1. OWNER Allied Gold Corporation  
 MAILING ADDRESS 9790 Gateway Dr. Ste 200  
Reno NV 89521

ADDRESS AT WELL LOCATION Sulfur to Imlay Rd.  
Hycroft mine  
 Subdivision Name: KP-DH-20 County: Pershing  
 Latitude \_\_\_\_\_ UTM E353608.94  NAD 27  
 Longitude \_\_\_\_\_ N4523602.82  NAD 83/WGS 84

2. LOCATION SW 1/4 NW 1/4 Sec 4 T 34 S R 29 E  
 PERMIT/WAIVER No. ma/1850  
Issued by Water Resources Parcel No.

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Sand loose Fine to coarse Dry Brn.		0	13'	13
Sand trace silt Dry Brn.		13	17	4
Sand Gravel Dense Brn.		17	23	6
Clay some Sand Hard moist Brn.		23	44	21
Clay Gravel Hard moist Brn.		44	53	9
Clay + Sand Hard Fine grain moist Brn.		53	62	9
Clay Sand Hard Brn.		62	73	9
Fine grain Brn.		122	128	6
Clay Sandy/Fine med grain Brn.		128	2505	122
Clay some Sand Hard Fine grain Brown				

9. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 199 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 250 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>		<u>Sch. 40</u>	<u>+2</u>	<u>199</u>

Perforations:  
 Type of perforation mill slot  
 Size of perforation 0.20  
 From 179 feet to 199 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement 0 to 20  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ~~200~~ Bentonite Grout 200 to 177  Pumped  Poured  
 Gravel Pack:  Yes  No 177 to 201  Pumped  Poured  
 Type: Silica Sand  
 Bentonite Chips:  Yes  No 201 to 250  Pumped  Poured  
 Type: SAT 8x16

Date started: 10-2 20 12  
 Date completed: 10-6 20 12

7. Water Level  
 Static water level: 172 feet below land surface  
 Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water Temperature: NA °F  
 Quality: \_\_\_\_\_

8. WELL TEST DATA		
TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Time (Hours)
<u>NA</u>	Draw Down (Feet Below Static)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name National EWP / Jim Whitley Contractor  
 Address 580 W. Silver St. Elko NV. 89001 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0075355  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2111  
 Signed Jim Whitley  
By driller performing actual drilling on-site or contractor  
 Date 10-19-12

(Rev. 09-08)

USE ADDITIONAL SHEETS IF NECESSARY

NAD27 40.850509°N, 118.735690°W