STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117964
Permit No.
Basin 076

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. ~~68643~~ 69160

1. OWNER Dean Sheldon
MAILING ADDRESS 55 Northridge
Fernley, NV 89408

ADDRESS AT WELL LOCATION 55 Northridge
Fernley, NV 89408
Subdivision Name: County:

2. LOCATION SW ¼ SE ¼ Sec 10 T 20N N/S R 24 E
PERMIT/WAIVER No. R3D-2012-11 (Issued by Water Resources) 020-153-04 Parcel No.

Latitude 39.60953N
Longitude -119.27239W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	72	72
Brown Clay		72	80	8
Sand & Gravel	XX	80	160	80

Date started: 21-Jun, 20 12
Date completed: 22-Jun, 20 12

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	20
6.625	4.0	.316	20	160

Perforations:
Type of perforation Saw Cut
Size of perforation 0.125
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 5 to 105 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 105 to 160 ☐ Pumped ☒ Poured
Type: 3/8" Well Gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 87 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2307
Signed (By driller performing actual drilling on site or contractor)
Date 7/2/2012

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-08)

RECEIVED 2012 JUL 24 AM 11:21 STATE ENGINEERS OFFICE

39.609617°N
119.271388°W NAD27