STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118044
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68457

1. OWNER Ben Peck / Weishaupt Family trust
MAILING ADDRESS 4020 Freeman IN
NE Fallon NV 89406

ADDRESS AT WELL LOCATION 4020 Freeman IN
Fallon NV 89406

2. LOCATION NW ¼ SW ¼ Sec 6 T 19 N/S R 31 E
PERMIT/WAIVER No. 009-171-09
Issued by Water Resources Parcel No.

Latitude
Longitude
Subdivision Name:

UTM E 366759 ☒ NAD 27
N 4377667 ☐ NAD 83/WGS 84
County: Churchill

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	35	34
Brown sand		35	40	5
Grey clay		40	70	30
Grey sands		70	80	10
Grey clay		80	110	20
Grey sand	X	110	120	10
Green clay		120	160	40
Green clays/ sand	X	160		
strings			246	86

* Original well log being replaced - UNKNOWN

RECEIVED
2012 JUN -1 AM 10:53
STATE ENGINEERS OFFICE

Date started 5-8, 2012
Date completed 5-15, 2012

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80		3

8. WELL CONSTRUCTION
Depth Drilled 246 Feet Depth Cased 246 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
17	Inches	0	Feet	100	Feet
4 7/8	Inches	100	Feet	246	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	32.75	.250	+1	100
6 5/8	12.9	.188	+2	246

Perforations:
Type of perforation Machine slot
Size of perforation .080
From 166 feet to 246 feet
From 106 feet to 126 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 246 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow 2 G.P.M < 2 P.S.I
Water temperature 179 °F Quality NOT Tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Drilling corp
Contractor
Address P.O. BOX 888
Contractor
Fallon NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1727
Signed Dave Anderson
By driller performing actual drilling on site or contractor
Date 5-28-12

(Rev. 06/10)

39.540221°N
118.550510°W
NAD27

USE ADDITIONAL SHEETS IF NECESSARY