STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118166
Permit No. 82128
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69509

1. OWNER ARTISAN EAST LLC
MAILING ADDRESS 4940 LEO BINGO CT
WASHOE VALLEY, NV 89704

ADDRESS AT WELL LOCATION 619 DRY CREEK TRAIL
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION SW ¼ SW ¼ Sec 28 T 34N N/S R 55 E
PERMIT/WAIVER No. 69713R09 (82128) 006-09P-070
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0601971 [X] NAD 27
N 4516796 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL STRIPPED				
BROWN SAND & FINE GRAVEL		0	10	10
GRAVEL w/ BOULDERS		10	15	5
FINE GRAVEL		15	30	15
BROWN GRAVEL w/ CLAY		30	40	10
GREEN CLAY w/ SAND		40	70	30
GREY BLACK CLAY		70	140	70
BLACK VOLCANIC TUFT	X	140	220	80
FINE GRAVEL w/ BROWN SAND	XX	220	240	20
1ST WATER	X	180		
2ND WATER	XX	200		

Date started: 24-Oct, 20 12
Date completed: 25-Oct, 20 12

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	240

Perforations:
Type of perforation PLASMA CUT
Size of perforation 3/16" X 4", 7 ROWS
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 4 to 24 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 55 to 240 [ ] Pumped [X] Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 24 to 55 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 79 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 64 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AT 220'	80		1 1/2 HOURS
AT 160'	60		1/4 HOUR
AT 120'	30		
AT 100'	15		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed (By driller performing actual drilling on site or contractor)
Date 10/29/2012

(Rev. 05-06) NAD27 40.797740°N 115.791258°W USE ADDITIONAL SHEETS IF NECESSARY